

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM

LISTING SERVICE

LISTING No. 7270-0075:195

Page 1 of 1

CATEGORY: Heat Detector

LISTEE: Fire-Lite Alarms, Inc., One Fire-Lite Place, Northford, CT 06472-1653
Contact: Brian Reynolds (203) 484-1200 Fax (203) 484-7309

DESIGN: Models H350, *H355, and *H355HT fixed temperature heat detectors. Models H350R and *H355R rate-of-rise with fixed temperature heat detectors. Refer to listee's data sheet for detailed product description and operational considerations.

RATING:

*H350, *H355, and *H355HT	135° F fixed temperature
*H350R and *H355R	15° F rate-of-rise
*H355HT	190° F fixed temperature

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes and ordinances and in a manner acceptable to the authority having jurisdiction.

MARKING: Listee's name, model number, electrical rating and UL label.

APPROVAL: Listed as heat detectors for use with separately listed compatible fire alarm control units.

Rev. 12-22-2002 JEW



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued: **DECEMBER 22, 2002**

*Listing Expires **June 30, 2003***

Authorized By: **DIANE K. AREND**, Senior Deputy
Program Manager